

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

1228
NE
> 1
1.596 mi.
8428 ft.

POLE 69261
IN FRONT 1310 AVE V
BROOKLYN, NY

NY Spills S113819171
N/A

Relative:
Higher

Actual:
18 ft.

SPILLS:

Name: POLE 69261
Address: IN FRONT 1310 AVE V
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 1304131 / 2013-08-16
Facility ID: 1304131
Facility Type: ER
DER Facility ID: 439794
Site ID: 484644
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2013-07-17
Investigator: RWAUSTIN
Referred To: Not reported
Reported to Dept: 2013-07-17
CID: Not reported
Water Affected: Not reported
Spill Source: Transformer
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2013-07-17
Spill Record Last Update: 2013-08-16
Spiller Name: ERT
Spiller Company: CON ED
Spiller Address: IN FRONT 1310 AVE V
Spiller Company: 999
Contact Name: ERT
DEC Memo: "8/16/13 - Austin - 1/2 gal dielectric fluid spill onto pavement,
from a pole transformer - Con Ed contained and cleaned up the spill,
and replaced the leaking transformer - See eDocs files for further
information - Spill closed - end"

Remarks: "onto concrete, c/u pending"

All Materials:

Site ID: 484644
Operable Unit ID: 1234321
Operable Unit: 01
Material ID: 2233330
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: .50
Units: Not reported
Recovered: Not reported
Oxygenate: Not reported